

Subject: Submission of unit price for new installation and repairing of 1 KVA, 2KVA and 3 KVA Online UPS for Prime Bank PLC.

Dear all,

Please refer to the captioned subject, we would to inform you that, Prime Bank PLC. intends to select a panel of vendors and unit price for a period of 6 (six) months for supply and installation of new 1 KVA, 2 KVA and 3 KVA Online UPS, repairing of old UPS at Head Office, Branches and ATM Booths throughout the Country. For this purpose, you are requested to submit financial offer in your letterhead pad as per following format/ specifications:

Table -01: On Line UPS (1 KVA):

Items	Required Specifications	Quoted Specifications	Unit Price
Brand	To be mention by the bidder		
Model	To be mention by the bidder		
Origin	To be mention by the bidder		
Capacity	1 KVA		
Backup Time	2 Hours at full Load		
Battery Type	Maintenance-free Sealed Lead acid		
Technology	VFI(VFI-SS-111), double conversion		
Wave Shape	Pure Sine Wave		
Input Voltage	160V-280V Single Phase		
Input Frequency	50/60 Hz (+/- 5%) Auto Sensing		
Input power factor/THDI	>0.98 (Full Load)		
System Voltage	24V/36V		
Battery Capacity	40Ah		
Recharge	6 to 8 hours		
Protection	Surge Protector		
Battery Weight	To be mention by the bidder		
Warranty	02 (two)Years including Battery		

Table -02: On Line UPS (2 KVA):

Items	Required Specifications	Vendor Response	Unit Price
Brand	To be mention by the bidder		
Model	To be mention by the bidder		
Origin	To be mention by the bidder		
Capacity	2 KVA		
Efficiency	To be mention by the bidder		
Backup Time	25 Minutes		
Battery Type	Maintenance free Sealed Lead Acid		
Technology	To be mention by the bidder		
Wave Shape	Pure Sine Wave		
Input Voltage	160V-280V, Single Phase		
Input Frequency	50/60 Hz(+/- 5%)		
Input Power Factor	>0.98(Full Load)		
System Voltage	96 V		
Battery Capacity	12 V/9Ah.		
Recharge	6 to 8 hours		
Alarms	Mains Fail, Charger Fail, Under/over voltage, Battery Low/Discharge, Over Temperature		
Protection(UPS shall trip on following faults)	Input AC Under/over voltage, Output overload/Short Circuit & Over Temperature (Surge Protector)		
Battery Weight	To be mention by the bidder		
Warranty	02 (two)Years including Battery		



Table -03: On Line UPS (3 KVA):

Items	Required Specifications	Quoted Specifications	Unit Price
Brand	To be mention by the bidder		
Model	To be mention by the bidder		
Origin	To be mention by the bidder		
Capacity	3 KVA		
Backup Time	2 Hours at full Load		
Battery Type	Maintenance-free Sealed Lead acid		
Form Factor	Tower		
Technology	VFI(VFI-SS-111), double conversion		
Wave Shape	Pure Sine Wave		
Input Voltage	160V-280V Single Phase		
Input Frequency	50/60 Hz (+/- 5%) Auto Sensing		
Input Power factor	>0.98 (Full Load)		
Output Voltage	220/230/240 V		
Output Frequency	50/ 60 Hz		
System Voltage	96V/120V		
Battery Capacity	65Ah		
Battery Brand	To be mention by the bidder		
Battery Origin	Taiwan		
Recharge	6 to 8 hours		
Battery Weight	To be mention by the bidder		
Warranty	02 (two)Years including Battery		

Table- 04: Battery OF 1/2/3 KVA ONLINE UPS

Type	Sealed Maintenance Free	Units	Rate
Battery Capacity per unit with cabinet	9Ah		
Battery Capacity per unit with cabinet	40Ah		
Battery Capacity per unit with cabinet	65Ah		
Brand & Origin	Should be mentioned	01	
Life Time	400 Cycle for 90% of the depth of Discharge		
System Voltage	240 V DC		
Warranty	02 (two) Years		

Table- 05: Old Online UPS Price (Buy-Back)

Item Description	Unit	Rate
1 KVA Online UPS Full Set	01	
2 KVA Online UPS Full Set	01	
3 KVA Online UPS Full Set	01	
Battery	01	

Terms & Conditions:

1. The supplier shall deliver the Online UPS and accessories to the Bank's selected location (anywhere in the country). No additional cost will be paid by the bank for transportation.
2. In case of supply of inferior quality/defective goods; any change required by Prime Bank must be entertained.
3. **Before installation of each Online UPS, the battery and machine must be cross checked by Administration Division.**
4. Payment will be made within 30 (thirty) days only after successful completion of works based on Challan, Work Completion Certificate by the respective vendor. Bank will deduct VAT & AIT as per Govt. rules.
5. Warranty: Standard Warranty of 02 years will be applicable. During this period, the vendor shall repair any kind of defects including replacement of any parts at their own cost.



6. Support Level: The Supplier shall provide immediate response either by phone, e-mail, and fax or by person to any of the Purchaser's queries related to support and service.
7. **Validity:** Offer shall remain valid for Six Months from the date of management approval.
8. After going through the terms & conditions, if you are interested to participate in the bidding process:

Please submit your proposal in your company's letterhead pad as per above mentioned format duly signed by your company's authorized representative in the tender box kept at Central Dispatch (Ground Floor), Head office, Prime Bank PLC., Plot # 08 & 35, Nikunja-2, Airport Road, Khilkhet C/A, Dhaka – 1229 on or before June 02, 2024 by 03:00 p.m. and clearly marked "Offer for Online UPS" on the top of the envelope. No quotations shall be dropped before or after this time period.

9. Bidder must submit photocopy of following documents along with the RFQ:

- a) Up-to-date Valid Trade License.
- b) Certificate of Incorporation in case of Limited Company.
- c) Valid TIN & BIN Certificate.
- d) Bank Solvency Certificate.
- e) Experience Certificate/Work Order.
- f) Client list.
- g) Technical Team profile

10. PBL reserves the right to accept or reject any quotation without any explanation.

For any kinds of Technical related issue please feel free to contact : Mr. Engr. Md. Sharifuzzaman, Cell : 01730197540

Thanking you.



Kazi Sohail Masud
AVP & Unit Head
Procurement-FMD