

Facility Management Division

Prime/HO/FMD/2024/Gen

December 03, 2024

Request for submission of proposal for supply, installation, testing & commissioning of 30KVA Diesel Generator Abu Torab Bazar Branch, Mirsarai, Chattogram.

Please accept our sincere gratitude to participate in the subject RFQ. You are hereby requested to submit financial proposal by <u>10 December 2024</u> for the subject matter as per below mentioned scope of work.

Name of Project as per RFQ Document	Last Date of Submission & Opening
30KVA (Diesel Engine) generator for Abu Torab Bazar Site Address: Al Madina Market, Abu Torab Bazar,	10 December 2024 (03.00 PM)
PS: Mirsharai, Dist: Chattogram	

Financial Proposal:

Qty.	Unit Price (TK)	Total (Including VAT & Tax)
4		
1		
	Qty.	Qty. Unit Price (TK)

Product Specification:

SL.	Technical Particulars	Prime Bank	Vendor's Response
1	Brand	Will be provided by Vendors	
2	Model	Will be provided by Vendors	
3	Country of Manufacturing	Will be provided by Vendors	
4	Country of Origin	USA/UK/EU/Japan	
5	Capacity (KVA)	30 KVA prime with variable load	
6	Starting System	Automatic Microcontroller based as well manual Start / Stop System	
7	Emergency Stop	Should be provided	
		ngine Part:	
8	Engine Type	Diesel Engine	
9	Engine Brand	PERKINS	
10	Speed (RPM)	1500 rpm	
11	Cooling	Water cooled (Radiator cooled with engine driven fan)	
12	Protection	Over and under speed, Low Oil pressure, Over heating etc.	
13	Fuel Tank Capacity (Ltr.)	Built in and Specified by the bidder	
14	Fuel Consumption per hour with 100%, 75%,50% load	Specified by the bidder	
15	Lube oil capacity (Ltr.)	Specified by the bidder	
16	Auto Charger	Specified by the bidder	
17	Governor type	Specified by the bidder	1 1

A



18	Maximum power at rated rpm, kw	Specified by the bidder						
	Alternator Part:							
19	Alternator Brand	Stamford						
20	Model	Specified by the bidder						
21	Frequency	50 HZ						
22	Phase	3-phase						
23	Voltage regulation	± 1% / ± 1.5% power factor between 0.8 lagging & unity						
24	Frequency regulation	0.25%						
25	Voltage	220V-230V						
26	Circuit Breaker rating & Breaking capacity	Mentioned by the bidder						
27	Circuit Breaker Brand	ABB/Relevant: Italy, France/Germany						
28	Cooling	Specified by the bidder						
29	Protection	Specified by the bidder						
30	Temperature Raise	Specified by the bidder						
	Sound	Proof canopy:						
		 OEM Factory Made (Should be fully 	6:					
	325	weatherproof sound attenuated						
		enclosure with residential silencer)						
	Sound Attenuated Canopy	Sound level should be less than						
31	•	67 dBA at 3m distance at 100%						
		load under free field condition 3. High quality noise absorbent and fire-retardant grade acoustic insulation material (P.U. Foam)						
32	Auto Transfer Switch (ATS) Local	Specified by the bidder						
		Others:						
33	Installation materials	Specified by the bidder						
34	Maintenance materials	Specified by the bidder						
35	Generator Installation	Specified by the bidder						
36	Periodic Service	Every 06 (six) months interval						
37	Generator weight (KG)	Specified by the bidder						
38	Generator dimension (LxWxH) (inch)	Specified by the bidder						
39	Control Module	Specified by the bidder						
40	Warranty	2 years from the date of installation. During this warranty period, if any problem occurs, vendor has to attend the site within 1 hour and resolve the issues.						
41	Ready Stock	Please mention the quantity						
42	Delivery Time & Location	Within 7 days after receiving WO						
43	Installation Materials, Earthing & others	Inclusive						
44	Civil work	Inclusive						
45	Site Visit	Inclusive						





1. Delivery & Installation:

- A. From ready-stock (Within 7 days after receiving WO).
- B. The supplier will deliver & install the products to the Bank's selected location. No additional cost will be paid by the bank for transportation.
- C. In case of supply of interior quality/defective goods; any change request by Prime Bank
- D. must be entertained.

2. The Tenderer shall submit with the following additional documents:

- A. Up-to-date valid Trade license.
- B. Bank solvency certificate.
- C. Updated Income tax clearance certificate.
- D. E-BIN registration certificate & e-TIN Certificate. (Up to date)
- E. The minimum work experience should be 5 (five) years in the related field.
- F. Practical work experience to execute such type of work for minimum amount of Taka 10 (ten) lac or above in a single work order.
- 3. Payment: Payment will be made within 30 (Thirty) days from receipt of bill from the supplier. Payment will be made as per the following terms and conditions:
 - A. 90% of the unit price will be paid after satisfactory installation of the equipment & subsequent certification of concerned division/concerned users.
 - B. Remaining 10% of total price will be paid to the supplier after 06 (Six) months of satisfactory operation of the equipment.
 - C. VAT, TAX inclusive, bank will deduct VAT & AIT as per govt. rules.
- 4. Please drop your tender 'Prime Tower (Ground Floor), Plot # 8 & 35, Nikunjo-2, Khilkhet, Airport Road, Dhaka-1219
- 5. Point of Contact: Md. Sharifuzzaman Al-Amin sharifuzzaman.amin@primebank.com.bd Cell: 01730197540
- 6. The Authority reserves the right to accept, modify or reject any or all of the proposals or may divide the works amongst the participants without assigning any reason whatsoever. Prime Bank is not bound to accept the lowest tender.

Thanking you.

Facility Management Division Tel: 09610990000-Ext. 11014