

Facility Management Division

Prime/HO/FMD/2024/Gen

December 05, 2024

Request for submission of proposal for supply, installation, testing & commissioning of 30KVA Diesel Generator at Chandina Branch, Cumilla.

Please accept our sincere gratitude to participate in the subject RFQ. You are hereby requested to submit financial proposal by <u>12 December 2024</u> for the subject matter as per below mentioned scope of work.

Name of Project as per RFQ Document	Last Date of RFQ Submission
30KVA (Diesel Engine) generator for Prime Bank Chandina Branch.	12 December 2024
Site Address: R.D.B. Plaza', Station Road, Chandina, Cumilla	(03.00 PM)

Financial Proposal:

Product Description	Qty.	Unit Price (TK)	Total (Including VAT & Tax)
30KVA Diesel Generator (Including installation)	1		×

Product Specification:

SL.	Technical Particulars	Prime Bank	Vendor's Response
		General	
1	Brand	Will be provided by Vendors	
2	Model	Will be provided by Vendors	
3	Country of Manufacturing	Will be provided by Vendors	
4	Country of Origin	USA/UK/EU/Japan	
5	Capacity (KVA)	30 KVA prime with variable load	
6	Starting System	Automatic Microcontroller based as well manual Start / Stop System	
7	Emergency Stop	Should be provided	
	Er	ngine Part:	
8	Engine Type	Diesel Engine	
9	Engine Brand	PERKINS	
10	Speed (RPM)	1500 rpm	
11	Cooling	Water cooled (Radiator cooled with engine driven fan)	
12	Protection Over and under speed, Low Oil pressure, Over heating etc.		
13	Fuel Tank Capacity (Ltr.)	Built in and Specified by the bidder	
14	Fuel Consumption per hour with 100%, 75%,50% load	Specified by the bidder	
15	Lube oil capacity (Ltr.)	Specified by the bidder	
16	Auto Charger	Specified by the bidder	
17	Governor type	Specified by the bidder	
18	Maximum power at rated rpm, kw	Specified by the bidder	

Prime Bank PLC., Head Office- Simpletree Anarkali, Holding No: 89, Plot No: 03, Block: CWS(A), Gulshan Avenue, Gulshan, Dhaka-1212, Bangladesh PABX: 880-2-223387265, 223390747-8, Fax: 880-2-55068685, E-mail: info@primebank.com.bd, SWIFT: PRBLBDDH, Website: www.primebank.com.bd



Marie 1	Alternator Part:						
19	Alternator Brand	Stamford					
20	Model	Specified by the bidder					
21	Frequency	50 HZ					
22	Phase	3-phase					
23	Voltage regulation	± 1% / ± 1.5% power factor between 0.8 lagging & unity					
24	Frequency regulation	0.25%					
25	Voltage	220V-230V					
26	Circuit Breaker rating & Breaking capacity	Mentioned by the bidder					
27	Circuit Breaker Brand	ABB/Relevant: Italy, France/Germany					
28	Cooling	Specified by the bidder					
29	Protection	Specified by the bidder					
30	Temperature Raise	Specified by the bidder					
		Proof canopy:					
31	Sound Attenuated Canopy	 OEM Factory Made (Should be fully weatherproof sound attenuated enclosure with residential silencer) Sound level should be less than 67 dBA at 3m distance at 100% load under free field condition High quality noise absorbent and fire-retardant grade acoustic insulation material (P.U. Foam) 					
32	Auto Transfer Switch (ATS) Local	Specified by the bidder					
		Others:					
33	Installation materials	Specified by the bidder					
34	Maintenance materials	Specified by the bidder					
35	Generator Installation	Specified by the bidder					
36	Periodic Service	Every 06 (six) months interval					
37	Generator weight (KG)	Specified by the bidder					
38	Generator dimension (LxWxH) (inch)	Specified by the bidder					
39	Control Module	Specified by the bidder					
40	Warranty	2 years from the date of installation. During this warranty period, if any problem occurs, vendor has to attend the site within 1 hour and resolve the issues.					
41	Ready Stock	Please mention the quantity					
42	Delivery Time & Location	Within 7 days after receiving WO					
43	Installation Materials, Earthing & others	Inclusive					
44	Civil work	Inclusive Inclusive					







1. Delivery & Installation:

- A. From ready-stock (Within 7 days after receiving WO).
- B. The supplier will deliver & install the products to the Bank's selected location. No additional cost will be paid by the bank for transportation.
- C. In case of supply of interior quality/defective goods; any change request by Prime Bank
- D. must be entertained.

2. The Tenderer shall submit with the following additional documents:

- A. Up-to-date valid Trade license.
- B. Bank solvency certificate.
- C. Updated Income tax clearance certificate.
- D. E-BIN registration certificate & e-TIN Certificate. (Up to date)
- E. The minimum work experience should be 5 (five) years in the related field.
- F. Practical work experience to execute such type of work for minimum amount of Taka 10 (ten) lac or above in a single work order.
- 3. Payment: Payment will be made within 30 (Thirty) days from receipt of bill from the supplier. Payment will be made as per the following terms and conditions:
 - A. 90% of the unit price will be paid after satisfactory installation of the equipment & subsequent certification of concerned division/concerned users.
 - B. Remaining 10% of total price will be paid to the supplier after 06 (Six) months of satisfactory operation of the equipment.
 - C. VAT, TAX inclusive, bank will deduct VAT & AIT as per govt. rules.
- 4. Please drop your tender 'Prime Tower (Ground Floor), Plot # 8 & 35, Nikunjo-2, Khilkhet, Airport Road, Dhaka-1219
- 5. Point of Contact: Md. Sharifuzzaman Al-Amin sharifuzzaman.amin@primebank.com.bd Cell: 01730197540
- 6. The Authority reserves the right to accept, modify or reject any or all of the proposals or may divide the works amongst the participants without assigning any reason whatsoever. Prime Bank is not bound to accept the lowest tender.

Thanking you.

Facility Management Division

Tel: 09610990000-Ext. 11014